

RiverSouth Rural Water District
Pump Station No. 5 Emergency Standby Generator and Transfer Switch
Tabulation of Bids Received on January 22, 2019, 10:00 a.m.
HWEI Project No. 2018102


SCHEDULE I				Duncan Construction, Inc.		Precise Heating, Air and Electric, Inc.		ACDC, Inc.	
Item#	Description	Quantity	Unit	Unit Cost	Bid	Unit Cost	Bid	Unit Cost	Bid
1.	Furnish and Install a 100 kW Emergency Standby Generator and Automatic Transfer Switch, concrete equipment pad, and sidewalk for operation and maintenance. The Bid shall include but is not limited to equipment, labor, materials, conduit, site work, electrical components, programming, and all appurtenances for a complete and operable installation. Applicable sales tax, shipping, generator startup, and operator training shall also be included in the Bid.	1	LS	\$49,197.00	\$49,197.00	\$50,158.00	\$50,158.00	\$57,036.00	\$57,036.00
TOTAL BID - SCHEDULE I					\$49,197.00		\$50,158.00		\$57,036.00

DEDUCTIVE ALTERNATE		Quantity	Unit	Unit Cost	Bid	Unit Cost	Bid	Unit Cost	Bid
DA1.	Delete the 100 kW Emergency Standby Generator and Transfer Switch and substitute a 50 kW Emergency Standby Generator and Automatic Transfer Switch and a 70 kW Alternator capable of handling Pump Station Loads and VFD Harmonics with Two (2) Pumps in Operation.	1	LS	\$40,882.00	\$40,882.00	\$43,750.00	\$43,750.00	\$52,930.00	\$52,930.00
TOTAL BID - SCHEDULE I, INCLUDING DEDUCTIVE ALTERNATE NO. 1					\$40,882.00		\$43,750.00		\$52,930.00

SCHEDULE I				Matlock Electric		Goodwin & Goodwin, Inc.	
Item#	Description	Quantity	Unit	Unit Cost	Bid	Unit Cost	Bid
1.	Furnish and Install a 100 kW Emergency Standby Generator and Automatic Transfer Switch, concrete equipment pad, and sidewalk for operation and maintenance. The Bid shall include but is not limited to equipment, labor, materials, conduit, site work, electrical components, programming, and all appurtenances for a complete and operable installation. Applicable sales tax, shipping, generator startup, and operator training shall also be included in the Bid.	1	LS	\$61,741.00	\$61,741.00	\$65,771.00	\$65,771.00
TOTAL BID - SCHEDULE I					\$61,741.00		\$65,771.00

DEDUCTIVE ALTERNATE		Quantity	Unit	Unit Cost	Bid	Unit Cost	Bid
DA1.	Delete the 100 kW Emergency Standby Generator and Transfer Switch and substitute a 50 kW Emergency Standby Generator and Automatic Transfer Switch and a 70 kW Alternator capable of handling Pump Station Loads and VFD Harmonics with Two (2) Pumps in Operation.	1	LS	\$53,041.00	\$53,041.00	\$57,271.00	\$57,271.00
TOTAL BID - SCHEDULE I, INCLUDING DEDUCTIVE ALTERNATE NO. 1					\$53,041.00		\$57,271.00

I hereby certify that this tabulation is a true and accurate representation of all bids received.



Jeremy D. Shoras, P.E.
Hawkins-Weir Engineers, Inc.
Arkansas P.E. No. 12386

